

Submittal Data


B-VFH24DA-1

Project Name:					
Location:					
Engineer:					
Submitted to:					
Submitted by:					
Reference:					
INDOO	R UNIT DAT	<u>4</u>			
Cooling Capacity	Btu/h	23800			
HeatingCapacity	Btu/h	27400			
Power Supply	Ph-V-Hz	1Ph,208/230V,60Hz			
Indoo	r Fan Motor				
Model		FG20E			
Input	W	124			
RLA	А	0.54			
<u>Air Flow</u>	v & Noise Lev	<u>vel</u>			
Indoor air flow	CFM	588.5/441/323			
Indoor noise level (H/M/	L) Db(A)	52/ 48/ 44			
<u>Phy</u>	vsical Data				
Dimensions (W*D*H*)	inch	43.3×24.2×7.9			
Packing (W*D*H*)	inch	52x29.1x11.4			
Net/Gross weight	lbs.	68.3/90.4			
Electric Box Li	quid Pipe (Gas Pipe			
		н			
		,			
	Drain Pipe				

J Downward Return Air

F

Approval:	
Date:	
Construction:	
Unit #:	
Drawing #:	



Model	А	В	С	D	E	F	G	Н		J
B-VFH24DA-1	45	19.33	41.8	40.2	43.3	24.2	46.5	6.1	7.9	25